REPUBLIC SERVICES

Sustainability in Action

# Wayne Disposal, Inc

## Permit No. MI0056413

## SSB Effluent August

| Sampling Date | Parameter | Limit | Unit | Result | Unit |
|---|---|---|---|---|---|
| 8/4/2025 | Total Phosphorus | 0.6 | lbs/day | 0.07 | lbs/day |
| 8/4/2025 | PFBS | 250 | ng/L | <2.0 | ng/L |
| 8/4/2025 | PFOA | 40 | ng/L | <2.0 | ng/L |
| 8/4/2025 | PFOS | 15 | ng/L | <2.0 | ng/L |
| 8/4/2025 | PFHxS | Monitor | ng/L | <2.0 | ng/L |
| 8/4/2025 | Chloride | Monitor | mg/L | 96.5 | mg/L |
| 8/4/2025 | Sulfate | Monitor | mg/L | 51.6 | mg/L |
| 8/5/2025 | Total PCBs | 0.1 | ug/L | <0.1 | ug/L |
| 8/12/2025 | Total PCBs | 0.1 | ug/L | <0.1 | ug/L |
| 8/20/2025 | Total PCBs | 0.1 | ug/L | <0.1 | ug/L |
| 8/28/2025 | Total PCBs | 0.1 | ug/L | <0.1 | ug/L |

*Total Phosphorus is based on the number of days the systems ran and how much was discharged