REPUBLIC SERVICES

Sustainability in Action

Wayne Disposal, Inc

Permit No. MI0056413

SSB Effluent July

Sampling Date	Parameter	Limit	Unit	Result	Unit
7/2/2025	Total Phosphorus	0.6	lbs/day	0.09	lbs/day
7/2/2025	PFBS	250	ng/L	<2.0	ng/L
7/2/2025	PFOA	40	ng/L	<2.0	ng/L
7/2/2025	PFOS	15	ng/L	<2.0	ng/L
7/2/2025	PFHxS	Monitor	ng/L	<2.0	ng/L
7/2/2025	Chloride	Monitor	mg/L	95.3	mg/L
7/2/2025	Sulfate	Monitor	mg/L	89.4	mg/L
7/3/2025	Total PCBs	0.1	ug/L	<0.1	ug/L
7/8/2025	Total PCBs	0.1	ug/L	<0.1	ug/L
7/16/2025	Total PCBs	0.1	ug/L	<0.1	ug/L
7/22/2025	Total PCBs	0.1	ug/L	<0.1	ug/L
7/28/2025	Total PCBs	0.1	ug/L	<0.1	ug/L

*Total Phosphorus is based on the number of days the systems ran and how much was discharged